


**Noted & Registered
at Serial Number**

689/2025



True Translation

Parbhani City Municipal Corporation Parbhani
Maharashtra Fire and Emergency Services
Apna Corner, Near Priti Talkies
Parbhani

Telephone no. 02452-223101

Toll Free No – 101

E-mail : fireservicespcmo101@gmail.com

Outword No – Pashmanpa/Awase/64/2025

Dated :18/03/2025

To,

Chief Administrative officer

Pathari Road, Parbhani

Subject : Annual Renewal of Fire No Objection Certificate

- Reference :
- 1) Your request application dated 20/02/2025
 - 2) Certificate of approved agent regarding fire prevention life protection
 - 3) Inspection report of Chief Fire Department dated 10/03/2025

Pursuant to the above subject, it is noted that, Saraswati Dhanwantari MESOC Foundations Ayurvedic Hospital Pathari Road, Parbhani (Building owner/ Developer/ Occupant) have submitted Form B from the Approved agent Dhanashree Fire Agency, Yaldarkar Colony, Parbhani (Fire prevention and life protection measures plan). According to the form B certificate submitted on 26/02/2025 all fire system tests conducted on 10/03/2025, it is satisfactory. Said NOC is valid for 1 year from the date of Issue. The responsibility for renewal of the certificate will be on your side. Care should be taken to ensure that the fire prevention and life protection measures found during the inspection will remain the same in the future.

Details of the building according to the map given by you, the use of the building is as follows.

S.No.	Form of Building	Usage
1	Ground Floor	Medical/Hospital
2	First Floor	Hospital
3	Second Floor	Hospital

CONDITIONS – As per Maharashtra Fire Prevention and Life Protection Measures Act 2006 it shall be mandatory to comply with the following terms and conditions.

- 1) Maharashtra Fire Prevention and Life Protection Measures Scheme Rule No. 3 The Applicant (Development / Standard / Occupant or as such may be designated) shall be bound to implement the

Fire Prevention and Life Protection Measures Scheme 2006 and National Building Code of India 2016 and any amendments thereto made from time to time. The concerned will keep vigilance that this law is not violated.

2) Section no. Sub-section (3) of sub-section (3) requires that the applicant has provided fire prevention and life-saving measures plans, and a certificate in the prescribed form from the fire department and a certificate in the prescribed form that the quantities specified in sub-section (1) have been corrected and kept in an efficient manner should be submitted to the Chief Fire Protection Officer twice per year in the month of January and July.

3) No person shall dismantle, alter, remove or otherwise cause any harm or damage to any fire prevention device installed in his premises or incite any person to do so.

4) After the advance prevention measure plan is in place in the said building and you have not received any notice regarding any errors in this previous system or any incident occurred in that building, this certificate will be accepted.

5) The amount of the difference between the fire service fee levied as per the Maharashtra Fire Prevention and Life Protection Measures Scheme Act, 2006 and the municipal fee should be paid at the time of taking the no objection certificate.

6) Taking into full consideration all the conditions given in the temporary no objection certificate and no other changes shall be made and if any changes are to be made in the said building, the changes/disputes should be brought to the attention of the undersigned.

7) The signatory reserves the right to make additional instructions subject to frequent changes in the relevant provisions.

8) It will be the responsibility of the applicant to rectify the error given in the electrical test report of the Maharashtra State Electricity Board, all the conditions are binding on the applicant and in case of violation, action will be taken by canceling the said No Objection Certificate.

Noted & Registered 689/2025
at Serial Number


Fire fighting officer

Fire and emergency services

Parbhani City Municipal Corporation Parbhani

BEFORE ME

VILAS A. DESHPANDE
NOTARY, GOVT. OF INDIA
PARBHANI





परभणी शहर महानगरपालिका परभणी

महाराष्ट्र अग्निशमन आणि वाणी सेवा
अपना कॉर्नर, प्रिती टॉकीज जवळ, परभणी



दफ्तरी क्र. 02452-223101 टोल फ्री क्र. 101ई-मेल: E-mail: fireservicespcmc101@gmail.com

जा.क्र.पशमनपा/आवअसे/ 64 /2025

दिनांक / 8 /03/2025

प्रति,
मुख्य प्रशासकीय अधिकारी,
पाथरी रोड, परभणी

विषय : अग्निशमन वार्षिक नुतनीकरण नाहरकत प्रमाणपत्र बाबत.

संदर्भ : 1) आपला विनंती अर्ज दिनांक 20/02/2025

2) आग प्रतिबंधक जीव संरक्षण बाबत मान्यता प्राप्त अभिकर्त्यांचे प्रमाणपत्र.

3) अग्निशमन विभाग प्रमुख यांची तपासणी दिनांक 10/03/2025 नुसार अहवाल

उपरोक्त विषयाच्या अनुषंगाने नमूद करण्यात येते की, मरुस्वती श्र्वंतरी मेनोक फॅडिशन आयुर्वेदिक हॉस्पिटल पाथरी रोड, परभणी येथील (इमारतीचे मालक/विकासक / भोगवटदार) यांनी दाखल केलेल्या मान्यता प्राप्त अभिकर्ता धनंती फावर एजन्सी, यलदरकर कॉलनी, परभणी अग्निशमन बंत्रणा दुरुस्त व कार्यक्षम असण्या बाबतचे (आग प्रतिबंधक व जीव संरक्षण उपाय योजना दिनांक 26/02/2025 रोजीच्या फॉर्म प्रमाणपत्र 'ब' नुसार दि. 10/03/2025 रोजी आग प्रतिबंधक साहित्य/ बंत्रणेची तपासणी केली ती समाधानकारक आहे तसेच सदरचे नाहरकत प्रमाणपत्र हे बरी केलेल्या दिनांकापासून 1 वर्षा पर्यंत वैध राहिल. यानंतर दरवर्षी अग्निशमन वार्षिक नुतनीकरण नाहरकत प्रमाणपत्र घेण्याचे सर्वस्वी जबाबदारी आपल्यावर राहिल, तसेच तपासणी दरम्यान आढळून आलेली आगप्रतिबंधक तसेच जीव संरक्षण उपाय योजना हि भविष्यात तशीच राहिल याची दक्षता घ्यावी. या आदी व याचीवर ना हरकत प्रमाणपत्र देण्यात येते.

इमारतीचा तपशील आपण दिलेल्या नकाशा नुसार इमारतीचा वापर खालील प्रमाणे आहे.

अ. क्र.	इमारतीचा स्वरूप	वापर
1	तळ मजला	मेडिकल / हॉस्पिटल
2	पहिला मजला	हॉस्पिटल
3	दुसरा मजला	हॉस्पिटल

- महाराष्ट्र आग प्रतिबंधक व जीव संरक्षण उपाय योजना अधिनियम २००६ नुसार खाली दिलेल्या अटी व शर्तीचे पालन करणे बंधनकारक राहिल अमिनामाने बंधनकारक राहिल (विकासक / मालक/भोगवटदार किंवा ज्या केलेल्या मुधारणे नुसार अंमलबजावणी करणे बंधनकारक राहिल. य कायद्याचे उल्लंघन होणार नाही याची दक्षता संवर्धित राहिल.
- सदर अधिनियमातील कलम क्र. 3 मधील पोट कलम 3 नुसार अर्जदाराने आग प्रतिबंधक जीव संरक्षण उपाय योजनांची तरतूद केली आहे या बाबतचे लायमन्स प्राप्त अभिकर्तांकडून दिलेले विधीन नमुन्यातील प्रमाणपत्र व पोटकलम (1) मध्ये विनिर्दिष्ट केल्या प्रमाणे दुरुस्त आणि कार्यक्षम स्थितीत ठेवल्या बाबतचे विधीन नमुन्यातील प्रमाणपत्र च मुख्य अग्निशमन अधिकारी यांच्याकडे वर्णानु दान वेळा जानेवारी व जुलै या महिन्यामध्ये सादर करावा.
- कोणतीही व्यक्ती आपल्या इमारतीत किंवा तीच्या लागत बसविलेली आग प्रतिबंधक उपकरण विधेडवणार नाही, त्यामध्ये फेरबदल करणार नाही, ते काढून टाकणार नाही किंवा त्याला कोणतीही हानी व नुकसान पोहचविणार नाही किंवा कोणत्याही व्यक्तीला तसे करणे बाबत नियावणी देणार नाही.
- सदर इमारतीत अग्निशमन प्रतिबंधक उपाय योजना मुन्विनीत असल्यानंतर तसेच या पूर्वी यंत्रणात काही त्रुटी आढळल्या बाबत आपणास नोटीस मिळाली नसेल किंवा त्या टिकाणी कुठलेही घटना घडलेली नसेल तर हे प्रमाणपत्र ग्राह्य घरण्यात येईल.
- महाराष्ट्र आगप्रतिबंधक व जीव संरक्षण उपाय योजना अधिनियम 2006 नुसार लावण्यात येणारी अग्निशमन सेवा फीस मनपा फीस नजर चुकीने कमी लावण्यात आल्यास होणारी फरकानी रक्कम ही नाहरकत प्रमाणपत्र घेते वेळेस भरावी लागेल.
- तात्पुरते नाहरकत प्रमाणपत्रांमध्ये दिलेल्या सर्व अटीच्या पुरतेम ग्राह्य धरून तसेच इतर कुठलेही बदल होणार नाही आणि सदर इमारतीत काही बदल करावयाचे असल्यास खालील स्वाक्षरीकाम वळवून बदल /वाढ करण्यात यावी.
- संवर्धनिक तरतुदीमध्ये बरंवार होणा-या बदलास अधिन राहून अनिरीक मूचना करण्याचा अधिकार सदर स्वाक्षरीक्यांने राखून ठेवण्यात आला आहे.
- महाराष्ट्र राज्य विद्युत मंडळ यांच्या विद्युत बाचणी अहवालांमध्ये दिलेल्या त्रुटीची पुर्तता करण्याची सर्वस्वी जबाबदारी अर्जदाराची राहिल, बरील सर्व अटी शर्ती अर्जदार यांना बंधनकारक असून याचा भंग आल्यास / केल्यास सदरील ना हरकत प्रमाणपत्र रद्द करून कार्यवाही करण्यात येईल

Rabind

अग्निशमन अधिकारी
अग्निशमन व आणीबाणीसेवा
परभणी शहर महानगरपालिका परभणी